

**E.1 ERRATA SHEET FOR DPU DESIGN & CONSTRUCTION STANDARDS –  
MARCH 20, 2024**

**Section 1.1.01 – General Design Requirements –  
Definitions**

Add the following definition:

- E. DESIGN AND CONSTRUCTION STANDARDS: This document and all the standards, specifications, and requirements contained herein, as adopted by the County for use and enforcement by the Department, and which define and describe the technical requirements and administrative processes by which water and sewer facilities in Goochland County, Virginia, shall be designed and constructed. May also be referred to as “the Standards”, “the Standards and Specifications”, or “these Standards”.

Adjust alphanumeric designation for other definitions as needed (F through X).

**Section 1.1.03 – General Design Requirements –  
Separation of Water Lines and Sewer Lines**

Add:

- E. Minimum Distance Between Service Connections
1. The minimum allowable distance between any two water service connections on a water line is 5.0 feet (60 inches).
  2. For one-inch water service connections on opposite sides of a water line, the minimum allowable distance between any two service connections is 2.5 feet (30 inches).
  3. The minimum allowable distance between a water service connection and any bell, tee, fitting or valve on a water line is 5 feet (60 inches).
  4. The minimum allowable distance between any two sewer service connections on a sewer line is 5.0 feet (60 inches).

**Section 1.3.07.A - Easement & Plat Requirements - Plat Preparation Requirements -  
All Utility Easement Plats shall meet the following requirements:**

Insert:

1. Easement plats shall be produced in NAD 83 State Plane Coordinate System.
2. A minimum of two coordinate points shall be provided on each plat sheet.

Renumber other items on the list of requirements as needed (3 through 11).

**Section 1.6.02.G.10 – Water Distribution Facilities - Miscellaneous Considerations**

Replace “Standard Drawings” with “appropriate Standard Details”.

**Section 4.5.08.H – Water Distribution System Installation - Tracer Wire & Access Boxes**

Replace “Section 5.1.24 of these Standards” with “Section 5.1.26 of these Standards”.

**Section 5.4.03.A – Approved Materials & Manufacturers – Sewer - Gravity Pipe - Polyvinylchloride**

Add:

5. Sanderson Pipe Corporation